

Filing Receipt

Received - 2022-02-08 07:48:08 AM Control Number - 52667 ItemNumber - 57



City of Granbury Project No. 52667 Compliance Report

This report was prepared by City of Granbury to comply with PUCT Project No. 52667 regarding the Filing of Attestations Demonstrating Compliance with HB 4150.

Report Date	January 13, 2022
Entity	City of Granbury
ERCOT Entity Type	Distribution Service Provider
Lake listed in PURA § 38.004(b) in SPEC Service Area	Lake Granbury
County of Lake and Distribution Line	Hood County, Texas

Line and Compliance Information

Line Identifier	Compliance with NESC 232	Compliance Date	Notes
Lake Crossing-1	No Line is de- energized	October 1, 2022	 Line was inspected in December-2019 and was determined to not meet NESC 232. Line was de-energized in 2020 and has been de-energized since this date. The engineering design required to bring the line into compliance was completed in May-2020. City of Granbury is working with engineering firm to obtain the services of a contractor that can complete the work required to bring line into compliance with NESC 232.
Lake Crossing-2	No	October 1, 2022	 Line was inspected in December-2019 and was determined to not meet NESC 232. The engineering design required to bring the line into compliance was completed in May-2020. City of Granbury is working with engineering firm to obtain the services of a contractor that can complete the work required to bring line into compliance with NESC 232.

PROJECT NO. 52667

FILING OF ATTESTATION DEMONSTRATING COMPLIANCE WITH HB 4150

AFFIDAVIT OF OFFICER FOR

CITY OF GRANBURY

FILED PURSUANT TO SECTION 6 HOUSE BILL 4150

STATE OF TEXAS §

COUNTY OF HOOD §

BEFORE ME, the undersigned authority, on this day personally appeared, and who, after being duly sworn, stated on his or her oath he or she is entitled to make this Affidavit, and that the statements contained below are true and correct.

I, Chris Coffman, swear or affirm that as a Municipal Utility operating in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system, confirms the following:

- City of Granbury operates a distribution utility system in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system;
- City of Granbury owns and operates (2) distribution lines over a lake listed in PURA § 38.004(b).
- These two (2) distributions power line crossings do not currently meet the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2). See attached Project No. 52667 Compliance Report for explanation and status.

(Signature of Officer of the Cooperative)

City Manager City of Granbury

Sworn and subscribed before me on this 17th day of February 2022.

Berrie Michaelle Mattock 03/30/2025

Notary Public in and for the State of Texas

Notary Seal

(Must be notarized by a notary public in and for the State of Texas

